



District of Columbia Department of the Environment  
**Underground Storage Tank Program**



## **REMINDER!!**

### **RELEASE DETECTION & CORROSION PROTECTION REQUIREMENTS**

**OWNERS OF HEATING OIL TANKS  
MUST PROVIDE A METHOD FOR RELEASE  
DETECTION (PURSUANT TO 20 DCMR § 6000.15) and  
CORROSION PROTECTION (20 DCMR §5901)**

**SUBMIT THE FOLLOWING TO DDOE BY NOVEMBER 30,  
DURING YOUR ANNUAL TANK REGISTRATION FEE:**

**1. COPY OF RELEASE DETECTION RECORDS**

(Tank Tightness Test (TTT) Results required once every 3 years or if you are using another method of release detection, your monthly test results for the last 12 months).

**2. COPY OF CATHODIC PROTECTION TEST  
RECORDS**

(Steel or metal tanks and lines require corrosion protection and should be maintained and tested once every 3 years).

**FAILURE TO SUBMIT YOUR RELEASE DETECTION &  
CATHODIC PROTECTION TEST RESULTS MAY RESULT  
IN AN ENFORCEMENT ACTION/FINE.**

**THANK YOU! Questions: Call/email 202-535-1950, [ust.ddoe@dc.gov](mailto:ust.ddoe@dc.gov) .**